



## GUIDELINES FOR FIRE PROTECTION

### Superbloom Festival 2025

**Organizer:** Superbloom Festival GmbH & Co. KG  
Pfuelstraße 5  
10997 Berlin

**Venue:** Superbloom Festival 2025  
Olympiapark München  
Spiridon-Louis-Ring 21  
80809 München

This document consists of: 1 cover sheet and 3 text sheets.

The disclosure, duplication and use in whole or in part without the consent of the author is expressly prohibited and will be prosecuted as copyright infringement.

# 1. General information

To ensure a smooth inspection of the entire site of Superbloom Festival 2025 again this year, we ask you to read the following guidelines carefully and to follow them.

A violation of these guidelines or other applicable regulations, guidelines and laws can, in the worst case, lead to exclusion from the event or the failure of official approval. In this case, constructions must be removed or modified at your own expense.

The original responsibility of the individual operators remains unaffected by these guidelines and other responsibilities.

## 2. Requirements

The following applies in principle:

- No flammable or highly flammable materials may be used.
- All materials must comply with at least class B1.
  - o Classification according to:
    - DIN 4102-1
    - DIN EN 13501-1 (corresponding)
- In special cases, see the requirements of the FIBauR or MVStättVO.
- If anything is unclear, you must contact us.

Furthermore, ignition sources must never be located near materials, including B1 materials.

### 2.1 Fire extinguishers

- The use of powder fire extinguishers is prohibited.
- Operators are obliged to carry out a risk assessment in advance in order to determine the necessary number of fire extinguishers.
- The personal requirement for fire extinguishers must be determined based on ASR 2.2.
- Fire extinguishers on the premises or other stand structures are not to be taken into account.
- Appropriate locations for fire extinguishers must be determined.
- In accordance to ASR A1.3, the locations must be marked with the F001 sign in a permanently visible and recognizable way.
- Extinguishing blankets are no longer state of the art and should not be used.
- When using hot cooking oil, metal covers must be kept close at hand.
- The operators are responsible for provision and monitoring.

## 2.2 Gas cylinders and systems

- The use of gas cylinders and systems must be registered with us in advance.
- Only 2 gas bottles may be present in the booth at the same time.
  - 1 gas bottle in operation (max. 11 kg)
  - 1 gas bottle to change (max. 11 kg)
  - All other gas cylinders must be stored in the lockable storage facilities provided for this purpose.
  - The respective locations will be announced to you by the divisional/area management after your arrival.
- The corresponding certificates must be available for gas cylinders and systems.
- DGUV V 79 and the associated technical regulations must be complied with.
- The evaluation of fire protection measures is carried out independently by each stand operator on the basis of TRGS 800.
- The operators themselves are responsible for the quantity to be kept, maintenance and testing of the systems.

## 2.3 Deep fryers

- The stand operator must independently implement and monitor the protective measures required for the operation of deep fryers in accordance with the applicable health and safety regulations.
- A suitable lid must be provided for each deep fryer.
- Deep fryers may only be operated if a sufficient number of grease fire extinguishers is available.
- Other fire extinguishers may also be held available, but must be positioned and marked in such a way that they cannot be used to extinguish grease fires.

## 2.4 Storage and disposal

- The storage of packaging material, cardboard boxes, paper, etc. outside the booths is prohibited.
- Waste containers may only consist of non-combustible material (metal).
- Each stand operator must ensure that there are always enough empty waste containers on their stand. Full waste containers must be exchanged for empty ones immediately.

## 2.5 Other hazardous materials

- Other hazardous substances - in particular those that are highly flammable or highly combustible - must be reported to us in advance.
- The stand operator is responsible for the appropriate storage, use and disposal in accordance with the current legal situation.

### 3. On site

- Escape and rescue routes, fire department access routes, bypasses and set-up areas must be kept clear at all times.
- Vehicles parked illegally will be moved or towed away at the owner's expense.
- Information on positions and the course of the mentioned areas can be obtained from the divisional/area management.
- Hydrants must remain freely accessible and must not be obstructed, blocked by parking or similar.
- Storage of material, vehicles or the like is not permitted on the areas mentioned, not even temporarily.
- In the event of a fire, the production department or event management must be notified immediately – even if the fire was extinguished independently.
- Operation of the area can only be resumed after the fire extinguishers used have been replaced.

### 4. Submissions

Available on site and can be checked on request:

- B1 certificate for all materials used
- test certificate for the gas system(s)

### 5. Contact

If you have any questions or difficulties, please contact the following person:

Thomas Bartz  
[thomas.bartz@konzeptsache.de](mailto:thomas.bartz@konzeptsache.de)